



EBNV.E10493 Conduit Fittings for Use in Hazardous Locations

Page Bottom

Conduit Fittings for Use in Hazardous Locations

OL

See General Information for Conduit Fittings for Use in Hazardous Locations

ADALET/SCOTT FETZER CO
4801 W 150TH ST
CLEVELAND, OH 44135 USA

E10493

Class I, Groups A, B, C and D; Class II, Groups E, F and G.

Conduit unions: Cat. Nos. XU-2, -3, -4, conduit sizes 1/2, 3/4, 1 in.

Close-up plug: Cat. Nos. OX-, followed by 2, 3, 4, 5, 6, 8, 10, 12, 14 or 16, conduit sizes 1/2 in. to 4 in.

Class I, Groups B, C and D; Class II, Groups E, F and G.

Conduit fittings for sealing: Cat. No. XYB followed by -2, -3 or -4 for vertical or horizontal mounting; 1/2, 3/4, 1 in. conduit sizes. For use only with the manufacturers Adaco No. 1 sealing cement.

Cat. No. XYB followed by -34 or -44 for vertical or horizontal mounting 1/2, 3/4 in. conduit sized. For use only with the manufacturer's Adaco No. 1 sealing cement.

Class I, Groups A, B, C and D; Class II, Groups E, F and G; Class III.

Drain/vent fitting, Type XDBH2, conduit size 1/2 in.

Class I, Groups C and D; Class II, Groups E, F and G.

Conduit fitting for sealing: Cat. No. XYB, followed by -5, -6, -8, -10, -12, -14 or -16 for vertical or horizontal mounting, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2 in. conduit sizes. For use only with the manufacturer's Adaco No. 1 sealing compound and Crouse-Hinds Chico sealing compound.

Cat. No. XYB followed by -54, -84, -104, -124, -144 or -164 for vertical or horizontal mounting 1, 1-1/4, 1-1/2, 2, 2-1/2 or 3 in. conduit sizes. For use only with the manufacturer's Adaco No. 1 sealing compound.

→ **Class I, Groups C and D; Class II, Groups F and G.** ←

→ **Drain/vent fittings:** Type XDB-2, conduit size 1/2 in. ←

Class I, Group D; Class II, Groups E, F and G.

Short-radius capped elbows (90 degree bend): Cat. Nos. FL-92 to -95 incl., conduit sizes 1/2, 3/4, 1 and 1-1/4 in. Cat. No. XJLD4, conduit sizes 1/2 to 2 in. incl.; Cat. Nos. XSO-884, -885, conduit sizes 1/2 to 3 in. incl.; Cat. No. XJTD4, conduit sizes 1/2 to 2 in. incl.; Cat. No. X82, conduit sizes 1/2, 3/4 in.; Cat. No. X83, conduit size 3/4 in.; Cat. No. X643, conduit sizes 1/2 to 1 in. incl.; Cat. Nos. XJBCC2, -3, -4, conduit sizes 1/2, 3/4, 1 in. respectively; Cat. Nos. XJLB-2, XJT-2, XJTB-2, conduit size 1/2 in.; Cat. Nos. XJU-2, -3, conduit sizes 1/2, 3/4 in.; Cat. No. XSO-663, conduit sizes 1/2 to 2 in. incl.

Conduit fittings for sealing: Cat. No. XY followed by -2, -3, -4, -5, -6. Vertical mounting only. Conduit sizes 1/2, 3/4, 1, 1-1/4, 1-1/2 in. For use with the manufacturer's Adaco No. 1 sealing compound and Crouse-Hinds Chico sealing compound.

Cat. No. XY followed by -34, -44 or -54, vertical mounting only. Conduit sizes 1/2, 3/4, 1 in. For use with the manufacturer's Adaco No. 1 sealing compound.

Cat. No. XYC followed by -2, -3, -4, -5, -6, -8, -10, -12, -14 or -16. May be followed by S. Conduit sizes 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4 in. For horizontal mounting except Cat. Nos. having S may be mounted either vertically or horizontally. For use only with the manufacturer's Adaco No. 1 sealing compound and Crouse-Hinds Chico sealing compound.

Cat. No. XYZ, followed by -34, -44, -54, -84, -104, -124, -144 or -164, may be followed by S. Conduit sizes 1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3 in. For horizontal mounting except Cat. Nos. housing S suffix may be mounted either vertically or horizontally. For use only with the manufacturer's Adaco No. 1 sealing compound.

Last Updated on 2012-02-03

[Questions?](#)

[Print this page](#)

[Notice of Disclaimer](#)

[Page Top](#)

© 2012 UL LLC

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from UL" must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "© 2012 UL LLC".